

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1288:150 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Gamewell, 60 Pleasant Street, Ashland, MA 01721
Contact: *Brian Reynolds (203) 484-1200 *FAX (203) 484-7309

DESIGN: Model "SmartNet" SN600-PC15, SN600-PC19 and SN600-PC19R proprietary receiving units. Each unit consists of an operator terminal and a CRT monitor. Units are intended for use with listee's listed Models Flex 630 and Flex 650 fire alarm control units (CSFM Listing No. 7170-1288:146 and 7165-1288:144) which serve as protected premises units. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as proprietary receiving units for use with listee's Models Flex 630 and Flex 650 fire alarm control units.

*Rev. 05-28-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**